

Review Date: 5/22/2020

## THE CITY OF NEW YORK DEPARTMENT OF ENVIRONMENTAL PROTECTION

Bureau of Environmental Compliance 59-17 Junction Boulevard, 9th Floor, Flushing, New York 11373 Records Control (718) 595-3855

## COMMERCIAL COAL / WOOD COOK STOVE CERTIFICATION

## A SUMMARY OF TEST RESULTS SHALL BE SUBMITTED ALONG WITH THIS CERTIFICATION FORM

Manufacturer Name:		Manufacturer Representative Name & Title:	
CAPTIVE AIRE SYSTEMS		BILL GRIFFIN, VP OF ENGINEERING	
Address:		Email:	
4641 PARAGON PARK		bill.griffin@captiveaire.com	
City / Town / Borough:	State Zip	Manufacturer's Website:	Phone:
RALEIGH	NC 27616	www.captiveaire.com	(717) 201-1420
COMMERCIAL COOK S		IONS CONTROL DEV	
BRAND NAME: CAPTIVE AIRE SYSTEMS INC			
TRADE NAME: POLLUTION CONTROL UNIT			
MODEL NUMBER: PCU-HE-ESP-ESP Size 1-7 with optional OC filters, KB/KB-INLINE/USBI/SIF Fan, CORE/CAS-EWC/EWC FS			
ANY ACCESSORIES INSTALLED TO ENHANCE OR SUPPORT THE OPERATION OF THE EMISSIONS CONTROL DEVICE: POllution Control Unit			
can be coupled with listed Type 1 commercial kitchen ventilation exhaust hood			
MAXIMUM AIR FLOW RATE: 36000 CFM OR as specified by Captive Aire's Pollution Control Unit			
EMISSIONS CONTROL DEVICE USED: Pollution Control Unit manufactured by Captive Aire Systems Including Multiple Listees			
UL METHOD USED:			
EPA METHOD USED: EPA Method 5, Appendix A-3 to CFR Part 60 / EPA Method 202, Appendix M to 40 CFR Part 51			
I hereby certified that testing of this commercial cook s Code of the City of New York and 15 RCNY Sections 3	love has been conducted in	accordance with the requirements set forth in	n Section 24-149.5 of the Administrative
SIGNATURE	PRINT NAME		DATE
WillBOM	BILL GRIFFIN, VP (	OF ENGINEERING	15-May-2020
FOR DEPARTMENT USE ONLY			
Certification #: CS ZOZO - COO		REMARKS:	4
		Centification	L. 1/11

Issuance Date:

PCUS by Captive Aire.