

THE CITY OF NEW YORK DEPARTMENT OF ENVIRONMENTAL PROTECTION

Bureau of Environmental Compliance 59-17 Junction Boulevard, 9th Floor, Flushing, New York 11373 Records Control (718) 595-3855

COMMERCIAL CHAR BROILER CERTIFICATION

A SUMMARY OF TEST RESULTS SHALL BE SUBMITTED ALONG WITH THIS CERTIFICATION FORM

Manufacturer Name:			Manufacturer Representative Name & Title:	
CAPTIVE AIRE SYSTEMS			Bill Griffin, VP of Engineering	
Address:			Email:	
4641 PARAGON PARK RD			bill.griffin@captiveaire.com	
City / Town / Borough: State Zip			Manufacturer's Website: Phone:	
RALEIGH	NC	27616	www.captiveaire.com	(717) 201-1420
COMMERCIAL CHAR BROIL	LER I	EMIS	SIONS CONTROL DEVICE	
BRAND NAME: Captive Aire Systems Inc.				
TRADE NAME: Pollution Control Unit				
MODEL NUMBER: PCU-PF-HE-HEPA followed by 1 thru 7 with optional OC filters, KB/KB-INLINE/USBI fan, CORE/EWC FS				
ANY ACCESSORIES INSTALLED TO ENHANCE OR SUPPORT THE OPERATION OF THE EMISSIONS CONTROL DEVICE: Pollution Control Unit				
can be coupled with listed Type 1 commercial kitchen ventilation exhaust hood.				
MAXIMUM AIR FLOW RATE: 36000 CFMs OR as specified by Captive Aire's Pollution Control Unit				
EMISSIONS CONTROL DEVICE USED: Pollution Control Unit manufactured by Captive Aire Systems including Multiple Listees				
ASTM METHOD USED:				
EPA Method USED: EPA Method 5, Appendix A-3 to CFR Part 60 / EPA Method 202, Appendix M to 40 CFR Part 51				
I hereby certified that testing of this commercial char broiler has been conducted in accordance with the requirements set forth in Section 24-149.4 of the Administrative Code of the City of New York and 15 RCNY Sections 37-02 and 37-06.				
SIGNATURE PRIN	IT NAME			DATE
Bill Griffin, VP of Eng			gineering	25-Oct-2017
<u> </u>				
FOR DEPARTMENT USE ONLY				
Certification #: $CB2C17-\infty$	4		REMARKS:	
REVIEWER'S USE ONLY Review Date: ID & Initials: Issuance Date: multiple units les				
10/30/2017 P.J.	Suance Da	te: 1, 20 i	multiple units in Captive Aire.	7